



Certificate of Compliance

Certificate: 1050142 (LR 104201-1)

Master Contract: 162396

Project: 2498315

Date Issued: February 24, 2012

Issued to: Data Industrial Corp.
A Div. of Badger Meter, Inc.
6116 East 15th St
Tulsa, OK 74112
USA
Attention: Sara J. Heiden

The products listed below are eligible to bear the CSA Mark shown



Eshwar Kashyap

Issued by: Eshwar Kashyap

PRODUCTS

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non -
Incendive Systems - For Hazardous Locations

Class I, Groups A,B,C,D; Class II, Groups E,F,G; Class III:

- Industrial Flow Sensors, Models 220CP, 220PV, 220BR, 220SS, 225 and 226, intrinsically safe when connected in accordance with installation drawing 06-480-001; and Models 220P, 228 and 250BR, intrinsically safe when connected in accordance with installation drawing 06-480-002.

Model numbers may include additional suffices to denote variations in mechanical construction.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2001) - General Requirements - Canadian Electrical Code, Part II

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CAN/CSA-C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations