






REVISIONS		
REV	DESCRIPTION	BY
C	ECO 3883	BH

T180	1	8.0	0.50	0.75	4.5
T160	1	6.0	0.50	0.75	6.5
T140	1	4.0	0.50	0.75	9.0
T125	2	2.5	0.50	NONE	10.0
T116B & T116S	4	1.625	0.50	NONE	12.0
T106B & T106S	6	0 - 1.25	0.25	NONE	12.0
T105	5	0 - 1.25	0.25	NONE	12.0
T100	7	3.0	0.25	NONE	12.0
PART NO.	FIG. NO.	A	B	C	D

BTU TEMPERATURE SENSORS- THERMISTORS							
DRAWN HMM		DATE 02 / 09 / 90		 Data Industrial		11 INDUSTRIAL DR MATTAPONSETT, MA 02739 (508) 758-6390	
CHECKED		DATE		PROJECT BTU METERS THERMOWELLS / THERMISTORS			
APPROVAL		DATE		PART THERMOWELL INSTALLATION DATA			
				SIZE B	FSCH NO.	DWG NO. 06-629-002	REV C
CD\SPEC CONTROL\06629002C.PRT						SCALE NONE	SHEET 1 OF 1